



AMERICAN PETROLEUM INSTITUTE

API Standard 653

Tank Inspection, Repair, Alteration, and Reconstruction

FIFTH EDITION | NOVEMBER 2014 | 162 PAGES | \$235.00 | PRODUCT NO. C65305

This standard covers steel storage tanks built to API 650 and its predecessor API 12C. It provides minimum requirements for maintaining the integrity of such tanks after they have been placed in service and addresses inspection, repair, alteration, relocation, and reconstruction.

The scope is limited to the tank foundation, bottom, shell, structure, roof, attached appurtenances, and nozzles to the face of the first flange, first threaded joint, or first welding-end connection. Many of the design, welding, examination, and material requirements of API 650 can be applied in the maintenance inspection, rating, repair, and alteration of in-service tanks. In the case of apparent conflicts between the requirements of this standard and API 650 or its predecessor API 12C, this standard shall govern for tanks that have been placed in service.

This standard employs the principles of API 650; however, storage tank owner/operators, based on consideration of specific construction and operating details, may apply this standard to any steel tank constructed in accordance with a tank specification.

This standard is intended for use by organizations that maintain or have access to engineering and inspection personnel technically trained and experienced in tank design, fabrication, repair, construction, and inspection.

This standard does not contain rules or guidelines to cover all the varied conditions which may occur in an existing tank. When design and construction details are not given, and are not available in the as-built standard, details that will provide a level of integrity equal to the level provided by the current edition of API 650 must be used.

This standard recognizes fitness-for-service assessment concepts for evaluating in-service degradation of pressure containing components. API 579-1/ASME FFS-1, *Fitness-For-Service*, provides detailed assessment procedures or acceptance criteria for specific types of degradation referenced in this standard. When this standard does not provide specific evaluation procedures or acceptance criteria for a specific type of degradation or when this standard explicitly allows the use of fitness-for-service criteria, API 579-1/ASME FFS-1 may be used to evaluate the various types of degradation or test requirements addressed in this standard.

For ordering information:

Online: www.api.org/pubs

Phone: 1-800-854-7179
(Toll-free in the U.S. and Canada)

(+1) 303-397-7056
(Local and International)

Fax: (+1) 303-397-2740

API members receive a 30% discount where applicable.

Contents

	Page
1 Scope	1-1
1.1 Introduction	1-1
1.2 Compliance with This Standard	1-1
1.3 Jurisdiction	1-1
1.4 Safe Working Practices	1-1
2 References	2-1
2.1 Referenced Publications	2-1
2.2 Other References	2-2
3 Definitions	3-1
4 Suitability for Service	4-1
4.1 General	4-1
4.2 Tank Roof Evaluation	4-1
4.3 Tank Shell Evaluation	4-2
4.4 Tank Bottom Evaluation	4-11
4.5 Tank Foundation Evaluation	4-16
5 Brittle Fracture Considerations	5-1
5.1 General	5-1
5.2 Basic Considerations	5-1
5.3 Assessment Procedure	5-1
6 Inspection	6-1
6.1 General	6-1
6.2 Inspection Frequency Considerations	6-1
6.3 Inspections from the Outside of the Tank	6-1
6.4 Internal Inspection	6-2
6.5 Alternative to Internal Inspection to Determine Bottom Thickness	6-6
6.6 Preparatory Work for Internal Inspection	6-6
6.7 Inspection Checklists	6-7
6.8 Records	6-7
6.9 Reports	6-7
6.10 Nondestructive Examination (NDE)	6-8
7 Materials	7-1
7.1 General	7-1
7.2 New Materials	7-1
7.3 Original Materials for Reconstructed Tanks	7-1
7.4 Welding Consumables	7-1
8 Design Considerations for Reconstructed Tanks	8-1
8.1 General	8-1
8.2 New Weld Joints	8-1
8.3 Existing Weld Joints	8-1
8.4 Shell Design	8-1
8.5 Shell Penetrations	8-1
8.6 Windgirders and Shell Stability	8-2

Contents

	Page
8.7 Roofs	8-2
8.8 Seismic Design	8-2
9 Tank Repair and Alteration	9-1
9.1 General	9-1
9.2 Removal and Replacement of Shell Plate Material	9-1
9.3 Shell Repairs Using Lap-welded Patch Plates	9-6
9.4 Repair of Defects in Shell Plate Material	9-8
9.5 Alteration of Tank Shells to Change Shell Height	9-8
9.6 Repair of Defective Welds	9-8
9.7 Repair of Shell Penetrations	9-9
9.8 Addition or Replacement of Shell Penetrations	9-9
9.9 Alteration of Existing Shell Penetrations	9-11
9.10 Repair of Tank Bottoms	9-15
9.11 Repair of Fixed Roofs	9-19
9.12 Repair of Floating Roofs	9-20
9.13 Repair or Replacement of Floating Roof Perimeter Seals	9-20
9.14 Hot Taps	9-21
10 Dismantling and Reconstruction	10-1
10.1 General	10-1
10.2 Cleaning and Gas Freeing	10-1
10.3 Dismantling Methods	10-1
10.4 Reconstruction	10-3
10.5 Dimensional Tolerances	10-5
11 Welding	11-1
11.1 Welding Qualifications	11-1
11.2 Identification and Records	11-1
11.3 Preheat or Controlled Deposition Welding Methods as Alternatives to Post-weld Heat Treatment (PWHT)	11-1
11.4 Welding Safety	11-3
12 Examination and Testing	12-1
12.1 NDE	12-1
12.2 Radiographs	12-3
12.3 Hydrostatic Testing	12-5
12.4 Leak Tests	12-8
12.5 Measured Settlement During Hydrostatic Testing	12-8
13 Marking and Recordkeeping	13-1
13.1 Nameplates	13-1
13.2 Recordkeeping	13-2
13.3 Certification	13-2
Annex A (informative) Background on Past Editions of API Welded Storage Tank Standards	A-1
Annex B (normative) Evaluation of Tank Bottom Settlement	B-1

Contents

	Page
Annex C (informative) Checklists for Tank Inspection	C-1
Annex D (normative) Authorized Inspector Certification	D-1
Annex E (Intentionally Left Blank)	E-1
Annex F (normative) NDE Requirements Summary	F-1
Annex G (informative) Qualification of Tank Bottom Examination Procedures and Personnel	G-1
Annex H (informative) Similar Service Assessment	H-1
Annex I (informative) Inquiries and Suggestions for Change	I-1
Annex S (normative) Austenitic Stainless Steel Storage Tanks	S-1
Annex SC (normative) Stainless and Carbon Steel Mixed Materials Storage Tanks	SC-1
Annex X (normative) Duplex Stainless Steel Storage Tanks	X-1
Figures	
4.1 Inspection of Corrosion Areas	4-4
4.2 Pit Measurement	4-5
5.1 Brittle Fracture Considerations	5-2
5.2 Exemption Curve for Tanks Constructed from Carbon Steel of Unknown Material Specification	5-3
9.1 Acceptable Details for Replacement of Shell Plate Material	9-2
9.2 Details for Door Sheets in Riveted Seam Tank	9-4
9.3 Details for Door Sheets in Lap Weld Seam Tank	9-4
9.4 Details for Door Sheet in Butt-Weld Shell Seam Tank—No Vertical Seam Offset	9-5
9.5 Details for Door Sheet in Bull-Weld Shell Seam tank—Vertical Seam Offset	9-5
9.6 Lapped Patch Repair Plates at the External Shell-to-bottom Joint	9-7
9.7 Typical Details for Addition of Reinforcing Plate to Existing Shell Penetration	9-9
9.8 Typical Details for Addition of “Tombstone” Shape Reinforcing Plate to Existing Shell Penetration	9-10
9.9 Method for Raising Shell Nozzles	9-12
9.10 Details for Installing a New Bottom Through an Existing Tombstone Reinforcing Plate	9-12
9.11 Details for Installing a New Bottom Through an Existing Tombstone Reinforcing Plate	9-13
9.12 Details for Installing a New Bottom Through an Existing Tombstone Reinforcing Plate	9-14
9.13 Typical Welded-on Patch Plates on Tank Bottom Plates	9-16
9.14 Hot Tap for Tanks	9-23
10.1 Tank Shell and Bottom Cut Locations	10-2
13.1 Nameplate	13-1
13.2 Certification Forms	13-4
B.1 Measurements of Shell Settlement (External)	B-2
B.2 Measurements of Bottom Settlement (Internal) Tank Out-of-service	B-2
B.3 Graphical Representation of Tank Shell Settlement per B.2.2.4	B-3
B.4 Graphical Representation of Shell Settlement per B.2.2.5	B-6
B.5 Graphical Representation of Shell Settlement per B.2.2.5	B-6
B.6 Edge Settlement	B-7
B.7 Correction for Measured Edge Settlement	B-8

Contents

	Page
B.8 Bottom Settlement Near Shell	B-9
B.9 Localized Bottom Depressions or Bulges Remote from Shell	B-10
B.10 Localized Tank Bottom Settlement Limits for Single Pass Welds	B-12
B.11 Maximum Allowable Edge Settlement for Areas with Bottom Lap Welds Approximately Parallel to the Shell	B-13
B.12 Maximum Allowable Edge Settlement for Areas with Bottom Lap Welds Approximately Perpendicular to the Shell	B-14
B.13 Edge Settlement with a Lap Weld at an Arbitrary Angle to the Shell	B-15
H.1 Steps in Conducting Similar Service Assessment	H-6
H.2 Example Corrosion Rate Curves for Bottom of Storage Tank	H-7
H.3 Example Corrosion Rate Curves for Top Course of Storage Tank	H-8
Tables	
4.1 Maximum Allowable Shell Stresses	4-7
4.2 Joint Efficiencies for Welded Joints	4-8
4.3 Joint Efficiencies for Riveted Joints	4-9
4.4 Bottom Plate Minimum Thickness	4-15
4.5 Annular Bottom Plate Thicknesses (in.)	4-15
6.1 Tank Safeguard	6-3
9.1 Hot Tap Connection Sizes and Shell Plate Thicknesses	9-22
10.1 Maximum Thicknesses on New Welds	10-3
10.2 Radii Tolerances	10-5
11.1 Welding Methods as Alternatives to Post-weld Heat Treatment (PWHT) Qualification Thicknesses for Test Plates and Repair Grooves	11-2
A.1 Editions of API Standard 650 and its Precursor, API Standard 12C	A-1
G.1 Suggested Essential Variables for Qualification Tests	G-6
H.1 Similar Service Product Classification	H-5